

**IEC****IECEE**

® TM

Ref. Certif. No.

CN44762-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Fuse-switch-disconnectors

Name and address of the applicant

Zhejiang GRL Electric Co.,Ltd.  
No.246 Wei 10th Road, Yueqing Economic Development Zone,  
Yueqing, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang GRL Electric Co.,Ltd.  
No.246 Wei 10th Road, Yueqing Economic Development Zone,  
Yueqing, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang GRL Electric Co.,Ltd.  
No.246 Wei 10th Road, Yueqing Economic Development Zone,  
Yueqing, Zhejiang Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Uimp:12kV; Ui:1000V; Ue:AC400V,AC690V;  
Ith=Ie:AC400V:630A,500A,425A,400A,315A; AC690V:500A,425A,400A,315A;  
Iq:100kA(AC400V),50kA(AC690V); AC-23B(AC400V), AC-21B(AC690V); 3P

Trademark / Brand (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

DNH1-630/30, DNH1-630/31, DNH1-630/30G,  
DNH1-630/31G

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 (5th Edition) + AMD1:2010 +  
AMD2:2014;IEC 60947-3:2008(3rd Edition) + AMD 1:2012 +  
AMD 2:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

03601-A-20CB0092-S-M1

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.09,2020

Signature:

Lu Mei

**CB 0059456**