



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE210304007440

Product

Fuse-switch Disconnecter

Applicant

Zhejiang GRL Electric Co.,Ltd.

No.246 Wei 10th Road, Yueqing Economic Development
Zone, Yueqing, Zhejiang Province, P.R.China

Type/Model

DNH7-400/30, DNH7-400/31;

Technical data

Ui:1000V;Uimp:12kV;Ue:AC400V:AC-23B;Ith=Ie:400A,35
0A,315A,
300A,250A,200A,160A;Ue:AC690V:AC-21B;Ith=Ie:315A,3
00A,250A, 200A,160A;Iq:100kA(400V), 50kA(690V);3P

This is to certify that, on the basis of the tests undertaken as per Report No.
CE2021CQC0304-012442, the submitted sample(s) of the above item complies with:

EN 60947-3:2009 + A1:2012 + A2:2015

and fulfills testing requirements of the European Directive:

2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Nov.12,2021

Valid until: Nov.12,2024

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE

